

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

SHIRLEY AND JOE E. WILLOUGHBY

COMPLAINANTS

v.

NICHOLAS COUNTY WATER DISTRICT

DEFENDANT

)  
)  
)  
)  
) CASE NO. 97-262  
)  
)  
)  
)

O R D E R

The defendant in this matter, in response to the Commission's Order to satisfy or answer the complaint involved herein, submitted a letter to the Commission on June 12, 1997, which stated that it had purchased a new pump and pressure switch which, according to the letter, were installed in a new pump station building on May 9, 1997. The old pump had been located in a pit near a creek, had been susceptible to flooding, and, in fact, burned up as a result of such flooding. The letter also stated that since the installation of the new pump, there have been no problems with pressure or service to customers on East Union Road. The complaint appearing to have been satisfied, the complainants, whose residence is located on East Union Road, were given the opportunity by letter of July 8, 1997, from the Commission's Executive Director, to state otherwise. No response having been received from the complainants, IT IS HEREBY ORDERED that the complaint in this matter is dismissed without prejudice.

Done at Frankfort, Kentucky, this 21st day of August, 1997.

PUBLIC SERVICE COMMISSION

Linda K. Breathitt  
Chairman

[Signature]  
Vice Chairman

B. J. Helton  
Commissioner

ATTEST:

Don Mills  
Executive Director